



Intelligent Transport Systems

Acceptable Product Record

Acceptance No:	ITS-AN000041
----------------	--------------

For:

Manufacturer	Natz Packaging
Product	Polymer Lid and Frame

Summary Scope:

Polymer Lid and Frame

Evaluation Reference:	ITS-EV0179	Approver	Manager TSI
Approver Signature:	<i>Raj J Roychoudhry</i>	Date	20 th March 2019

A) Description and itemisation of the equipment covered by the Acceptable Product Record:

Natz Packaging Polymer Lid and Frame Model: W-LIDASSYLGE-211

B) Relevant Specifications, Drawings and Standards:

RMS Specification: TSI-SP-055 v2.0

C) Scope of use for which acceptance applies:

Pit Covers & Frames

D) Concession for Non-compliance:

- 1) Sizing - The sizing does not meet RMS requirements as stated in TSI-SP-055 v2.0. The 'small' RMS pavement junction lid and frame in TSI-SP-055 v2.0 is to have a minimum clear opening of 330mm x 270mm, the dimension of this product is 377mm x 255mm.
- 2) Water ingress prevention is not addressed by this product.

E) Conditions of use

- 1) Certificate users shall verify with RMS whether this certificate is current and valid, when using in situations where current validity is required.
- 2) For use in underground fuse pits as an access lid and frame in lieu of the cast iron lid and frame.

F) Related Acceptable Product Record History.

Acceptance No	Issued	EV Number	Description or change details